



# HVAC VALIDATION CERTIFICATE



Certificate No: UK0018P

awarded to

**Acıbadem Sağlık Grubu Genel Müdürlük  
Labcell Hücre Laboratuvarı ve Kordon Kanı Bankası  
HVAC System is complying with  
ISO Class 5 Cleanroom Requirements.**

**MEETS OR EXCEEDS THE REQUIREMENTS OF ISO 14644-1:2001 CLASS 5  
FEDERAL STANDARD 209E CASS 1,000  
AT 0.5 MICRON IN THE REST MODE**

*presented by*



**MAVI HAVA TEST KONTROL MUH.LTD.STI**

Validation Date :16.18.07.2012 Revalidation Date : July 2013

Validation Report No : 08/200 Certification No: 08/200

**ÖZLEM SEÇKİN**

This certificate shall not be re-issued, reproduced or change without written approval of MAVI Hava Test Kontrol Muh.Ltd.Sti.  
The above measurements and results represent only for the time and place of inspection.

MAVI Hava Test Kontrol Muh.Ltd.Sti has no responsibility or guarantee for the change in the inspection result due to changes in the inspection place after inspection.